

## PLUMBING FIXTURE SCHEDULE

## WATER FILTER SCHEDULE

## EQUIPMENT ROUGH-IN SCHEDULE

## PLUMBING PUMP SCHEDULE

## STORAGE TANK SCHEDULE

1. EQUIPMENT FURNISHED BY OTHERS, P.C. TO PROVIDE NECESSARY PLUMBING CONNECTIONS TO EQUIPMENT. COORDINATE PLUMBING CONNECTIONS WITH EQUIPMENT SUPPLIER.
2. REFER TO ARCHITECTURAL SPECIFICATIONS AND SUBMITTALS FOR FURTHER INFORMATION ON EQUIPMENT.
3. THIS UNIT REQUIRES INDIRECT DRAIN CONNECTION. PROVIDE FULL SIZE DRAIN PIPE FROM UNIT TO ASSOCIATED DRAIN.
4. STEAM STERILIZER REQUIRES 3/4" NPT CONNECTION FOR STEAM PIPING WHICH IS SHOWN ON MECHANICAL DRAWINGS.
5. COLD WATER CONNECTION TO HOSE BIBB.
6. PROVIDE PRESSURE REGULATOR ON LA - INLET PRESSURE 100 PSI; SET FOR OUTLET PRESSURE 50 PSI.
7. PROVIDE PRESSURE REGULATOR ON LA - INLET PRESSURE 100 PSI; SET FOR OUTLET PRESSURE 30 PSI.

# WATER SOFTENER SCHEDULE

## PACKAGED REVERSE OSMOSIS SCHEDULE

## CONSULTANTS:

**ARCHITECT/ENGINEERS:**

Drawing Title				
PLUMBING SCHEDULES				
Approved: Medical Center Director	Approved: Chief of O.R.	Approved: Chief of SPD	Approved: Director of Facilities Management	Approved: Infection Control/ Nurse Practitioner

Project Title			
STERILE PROCESSING AND DISTRIBUTION			
Location			
HARRY S. TRUMAN VAMC			
Date	Checked	Drawn	Approved
1/13/12	CKF	JGM	

Project Number <b>589-321</b>
Building Number <b>1</b>
Drawing Number <b>PL601</b> Dwg. 52 of 95